



#### NOTES:

1. ELECTRIC METER AND PRIMARY DISCONNECT MOUNTED TO UNI-STRUT ON BACK SIDE OF PANEL.
2. EMERGENCY GENERATOR RECEPTACLES: RUSSELL & STOLL, JRSB 1044FR ( 100 AMP ), 2044FR ( 200 AMP ).
3. ALL POWER AND CONTROLS LINES SHALL BE CONTINUOUS ( NO SPLICES ).
4. POWER SUPPLY MECHANICALLY INTERLOCKED.
5. PHASE MONITOR ON 460 + VOLT SERVICE.
6. GROUND FAULT INTERRUPTER ON CONVENIENCE RECEPTACLE.
7. 1.5 K.V.A. TRANSFORMER ON 460+ VOLT SERVICE.
8. PANEL MOUNTED TO S/S UNI-STRUT BY WELDED TABS.
9. CONTROL PANEL SHALL BE UL LISTED AS A UNIT.
10. TELEMTRY CONDUIT SHALL BE INSTALLED BY THE CONTRACTOR WITH SWEEP 90 DEGREE BEND IN DIRECTION OF TOWER AND EXTENDED BEYOND SLAB.
11. ALL HARDWARE, NUTS & BOLTS, AND APPURTENANCES ABOVE GROUND SHALL BE 316 STAINLESS STEEL.
12. INSTALLATION SHALL MEET NFPA ELECTRICAL CODE.



### ST. LUCIE COUNTY WATER & WASTEWATER CONSTRUCTION STANDARDS

### TYPICAL PUMP STATION CONTROL PANEL

DRAWING NUMBER: **WW-26**